



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	3/10/09	Interpretation	08-085
Topic	Automatic Smoke Detection Requirements for Group E Day Care Facilities		
Code Section(s)	2007 California Fire Code Section 907.2.3, 907.2.3.2		
Requested by	Cesar Fortuno Pyro-Comm Systems, Inc. 15531 Container Lane Huntington Beach, CA 92649-1530 (714) 902-8000 <a href="mailto:cfortuno@pyrocomm.com">cfortuno@pyrocomm.com</a>		

**Is it the intent of the code to provide smoke detectors in every room and area of the building or in the classrooms and rooms used for day care purpose, to comply with automatic fire alarm system requirement for a new private elementary and high school?**

Yes. Every new Group E/I-4 Day Care facility shall be provided with an automatic smoke detection system interconnected to the building fire alarm system.